



**Environmental and Laboratory Services**  
 90 ½ West Blackwell St., Dover, New Jersey 07801  
 (973) 989-0010 P, (973) 989-0156 F

## Analytical Results

Date: April 20, 2017

Client: Riverdale Public Schools  
 Address: 52 Newark Pompton Turnpike  
 Riverdale, NJ 07457

Project: Grade Levels Pre K-8th

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5135-1  
 Sample location: Field Blank  
 Sampled by: D. Diaz  
 Sample date: 04/07/17  
 Time: 06:23  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	04/13/17	18:46	1	2 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5135-2  
 Sample location: Hallway by Room 10 (RD-FC-C4-by 10)  
 Sampled by: D. Diaz  
 Sample date: 04/07/17  
 Time: 06:24  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	04/13/17	18:53	1	2 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5135-3  
 Sample location: Room 01C (RD-SO-01C)  
 Sampled by: D. Diaz  
 Sample date: 04/07/17  
 Time: 06:39  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	17.0 µg/L	15 µg/L	04/13/17	19:00	1	2 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5135-4  
 Sample location: Hallway by Room 03 (RD-FC-CI-By03)  
 Sampled by: D. Diaz  
 Sample date: 04/07/17  
 Time: 06:41  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	04/13/17	19:06	1	2 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5135-5  
 Sample location: Room 03 (RD-SO-03)  
 Sampled by: D. Diaz  
 Sample date: 04/07/17  
 Time: 06:44  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	6.70 µg/L	15 µg/L	04/13/17	19:12	1	2 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5135-6  
 Sample location: Room 04 (RD-SO-04)  
 Sampled by: D. Diaz  
 Sample date: 04/07/17  
 Time: 06:46  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	4.42 µg/L	15 µg/L	04/13/17	19:26	1	2 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5135-7  
 Sample location: Room 28 Nurse by Door (RD-MO-28-01)  
 Sampled by: D. Diaz  
 Sample date: 04/07/17  
 Time: 06:30  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.00 µg/L	15 µg/L	04/13/17	19:32	1	2 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5135-8  
 Sample location: Hallway by Room 18 (RD-FC-C6-01-by 18)  
 Sampled by: D. Diaz  
 Sample date: 04/07/17  
 Time: 06:34  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	04/13/17	19:39	1	2 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5135-9  
 Sample location: Hallway by Room 18 (RD-FC-C6-02-by 18)  
 Sampled by: D. Diaz  
 Sample date: 04/07/17  
 Time: 06:36  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	04/13/17	19:45	1	2 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5135-10  
 Sample location: Hallway by Room 38 (RD-FC-C8-by 38)  
 Sampled by: D. Diaz  
 Sample date: 04/07/17  
 Time: 06:27  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	04/13/17	19:52	1	2 µg/L

µg/L= micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Laurette Young (For SV)  
 Susan VanVeen, Lab Manager  
 NJ Laboratory Certification ID # 14013

April 20, 2017  
 Date